



No.F6/DFS/MS/School/SZ/2025/ 821

Dated: 24/06/2025

FIRE SAFETY CERTIFICATE

Certified that the Khadijatul Kubra Girls Public School located at 8/1, Joga Bai, Jamia Nagar, New Delhi-25, was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2021/SZ/1016 dated 16.12.2021. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 17.06.2025 in the presence of Mr. Talha (Manager) and found that the school building is comprised of two block namely:- Sr. Block - Basement (found closed) + Ground + 03 upper floors & Jr. Block - Sunken Ground+ Lower Ground + Ground + 03 upper floors, both blocks are interconnected at each floor level. The school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. 262-362 Dated-17/01/2005 issued by the Director of Education and the building is fit for occupancy of Group B "Educational Building" with effect from 24/06/2025 renewed for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on... 24/06/2025at New Delhi by

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Khadijatul Kubra Girls Public School located at 8/1, Joga Bai, Jamia Nagar, New Delhi-25.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.

Principal
Khadijatul Kubra Girls School
8/1, Jogabai, Jamia Nagar
New Delhi-110025

MANAGER
Khadijatul Kubra Girls Public School
8/1, Joga Bai, New Delhi-110025